



3933 US Route 11
 Cortland, New York 13045 USA
 Phone Number: (800) 345-3851
 Fax Number: (607) 758-6637
 Web: www.intertek.com

Intertek

ETL Verified Certificate of Conformance Number: 100375017CRT-001f

On the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the essential requirements of the referenced specifications at the time the tests were carried out.

Rendered to:


Universal Cabling Systems Inc.

2485 Huntington Drive #218
 San Marino, CA 91108 USA

Contact: Ms. Megan Hsu

Product Tested

6-Connector Channel
 Near End



Component ID	Manufacturer	Part Number	Description
1, 5, 9	UCS	PC6U-455XXX-XX	Equipment Cord, 3m
2, 4, 12	UCS	A5JX-U6E01-XX	Wall Outlet
3, 7, 11	UCS	C60X04-305-XX	Horizontal Cable
6	UCS	A7TL-UX110-XXX	110 Block
8, 10	UCS	A7PP-ALAXXX-XX	Patch Panel
13	UCS	PC6U-455XXX-XX	Equipment Cord, 1m

Standard(s)/Specification ANSI/TIA-568-C.2 Category 6 with the applicable electrical transmission characteristics

Product(s) Literature May Include: ETL Verified 6-Connector Channel to ANSI/TIA-568-C.2 Category 6, along with channel illustration, and parts numbers.

Continuing compliance to this specification is monitored through production testing, ongoing inspections by Intertek at the production facility and random sample testing.

Date Issued: June 08, 2011

Date Revised: February 18, 2017

Approved By: *Antoine Pelletier*
 Antoine Pelletier, Project Engineer

This verification supersedes all previous verifications with the noted Verification/Report number(s) dated before this verification notice.

NOTE: This verification is part of the full test report(s) and should be read in conjunction with it.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.