

Issue Date: 12-22-2016
Revision Date 12-09-18
Renewal Date: 01-01-20

DIVISION: 07 00 00 – THERMAL AND MOISTURE PROTECTION

Section: 07 53 23 – Ethylene-Propylene-Diene-Monomer Roofing

REPORT HOLDER:

Mule-Hide Products Co., Inc.
1195 Prince Hall Drive
Beloit, WI 53511
800-786-1492
www.mulehide.com

REPORT SUBJECT:

Mule-Hide Roof System

1.0 SCOPE OF EVALUATION

1.1 This Research Report addresses compliance with the following Codes:

- 2018, 2015 and 2012 *International Building Code*® (IBC)
- 2018, 2015 and 2012 *International Residential Code*® (IRC)
- 2017 *Florida Building Code* (FBC) (see Section 9)

1.2 The Mule-Hide Roof System with FR Adhesive has been evaluated for the following properties (see Table 1):

- Fire Classification
- Wind Uplift Resistance

1.3 The Mule-Hide roof system with FR Adhesive has been evaluated for the following uses:

- Fire classified roofing assemblies

2.0 STATEMENT OF COMPLIANCE

The Mule-Hide Roof System with FR Adhesive complies with the Codes listed in Section 1.1, for the properties stated in Section 1.2, and uses stated in Section 1.3, when installed as described in this report, including the Conditions of Use stated in section 6.0.

3.0 DESCRIPTION

3.1 FR Adhesive:

The FR Adhesive contains fire retardants and is an acrylic water-based bonding adhesive for adhering EPDM membrane directly to OSB or plywood substrate roof systems. The adhesive is supplied in 5-gallon, 55-gallon, and 330-gallon totes with a 1 year shelf life.

3.2 EPDM Roofing Membranes:

The EPDM membrane must be Mule-Hide EPDM, either 0.045 inch or 0.060 inch thick, recognized in ICC-ES ESR-1463.

4.0 PERFORMANCE CHARACTERISTICS

4.1 Fire Classification: The fire classification of the roof system is Class C.

4.2 Wind Uplift Resistance: The allowable uplift resistance for the roof system is 120 psf, which reflects the ultimate pressure divided by the safety factor of 2.0.

5.0 INSTALLATION

5.1 General:

The Mule-Hide Roof System with FR Adhesive must be installed in accordance with the manufacturer's published installation instructions, the applicable Code, and this Research Report. A copy of the manufacturer's instructions must be available on the jobsite during installation.

5.2 Application:

FR Adhesive is used for adhering EPDM membrane directly to OSB or plywood substrate roof systems. The roof system must be installed at a minimum slope of



1/4:12 and a maximum slope of 1:12. The roof deck must be minimum 7/16 inch thick OSB or minimum 1/2 inch thick plywood. The OSB must comply with US DOC PS 2 and the plywood must comply with US DOC PS 1 or PS 1. The EPDM membrane must be immediately rolled onto the wet adhesive. The adhesive must be applied at a coverage rate of 100 to 120 square feet per gallon.

6.0 CONDITIONS OF USE

6.1 Installation must comply with this Research Report, the manufacturer's published installation instructions, and the applicable Code. In the event of a conflict, this report governs.

6.2 The EPDM membrane must be Mule-Hide EPDM recognized in ICC-ES ESR-1463.

6.3 The roof deck to which the Mule-Hide Roof System is applied must be designed for the applicable wind loads.

6.4 The FR Adhesive is manufactured in Memphis, Tennessee under a quality program with inspections by Intertek Testing Services NA, Inc..

7.0 SUPPORTING EVIDENCE

7.1 Reports of tests in accordance with ASTM E108 and UL1897.

7.2 Documentation of an Intertek approved quality control system for the manufacturing of products recognized in this report.

8.0 IDENTIFICATION

The FR Adhesive is identified with the Mule-Hide Products Co., Inc. name, address, and telephone number, the

product name (FR Adhesive), batch number, the Intertek Mark, and the Code Compliance Research Report number (CCRR-1078).

9.0 OTHER CODES

9.1 Scope of Evaluation:

The Mule-Hide Roof System with FR Adhesive was evaluated for compliance with the *2017 Florida Building Code – Building*.

9.2 Conclusion:

The Mule-Hide Roof System with FR Adhesive, described in Sections 2.0 through 7.0 of this Research Report, complies with the *2017 Florida Building Code – Building*, subject to the following condition:

- Use of the Mule-Hide Roof System with FR Adhesive for compliance with the High-Velocity Hurricane Zone provisions of the *2017 Florida Building Code – Building* is outside the scope of this Research Report.
- Intertek is a Florida State Product Evaluation Entity.

10.0 CODE COMPLIANCE RESEARCH REPORT USE

10.1 Approval of building products and/or materials can only be granted by a building official having legal authority in the specific jurisdiction where approval is sought.

10.2 Code Compliance Research Reports shall not be used in any manner that implies an endorsement of the product by Intertek.

10.3 Reference to the Intertek website address: <https://bpdirectory.intertek.com> is recommended to ascertain the current version and status of this report.





This Code Compliance Research Report ("Report") is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Report. Only the Client is authorized to permit copying or distribution of this Report and then only in its entirety, and the Client shall not use the Report in a misleading manner. Client further agrees and understands that reliance upon the Report is limited to the representations made therein. The Report is not an endorsement or recommendation for use of the subject and/or product described herein. This Report is not the Intertek Listing Report covering the subject product and utilized for Intertek Certification and this Report does not represent authorization for the use of any Intertek certification marks. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.



Intertek

545 E. Algonquin Road • Arlington Heights • Illinois • 60005
intertek.com/building





TABLE 1 – PROPERTIES EVALUATED

PROPERTY	IBC/FBC SECTION	IRC SECTION	STANDARD
Wind Uplift Resistance	1504.3.1	R905.1	UL 1897
Fire Classification	1505.1	R902.1	ASTM E108