

**PUBLIC NOTICE**

**Intertek Warns of Unauthorized ETL Certification Mark on Huizhou Faith Electric Manufacture (Smart Electrician) Receptacle Type Ground-Fault Circuit-Interrupters**

Published: September 1, 2017

The following is a notification from Intertek that the Receptacle Type Ground-Fault Circuit-Interrupters manufactured by Huizhou Faith Electric Manufacture identified below bears unauthorized Intertek Certification Marks for the United States and Canada. These products were previously found to be non-compliant, subsequently terminated in 2015 and continue to be found in the marketplace today.

<b>Product Description</b>	<i>Receptacle Type Ground-Fault Circuit-Interrupters Model GLX-15ATR under the brand name Smart Electrician</i>
<b>Manufacturer</b>	<i>Huizhou Faith Electric Manufacture</i>
<b>Number of Units</b>	<i>Unknown</i>
<b>Identification</b>	<i>On Product: .<b>ETL</b><sub>us</sub> certification mark with Control Number 4008942, identifying model as GLX-15ATR. The inspection tag shows date of manufacturing of 2016-45. See also product photos below.</i>
<b>Reported Hazards</b>	<i>Products may fail to properly break a circuit in a fault</i>
<b>Sold at</b>	<i>Known to be sold at Menards (<a href="http://www.menards.com">http://www.menards.com</a>) and may be sold by other retailers.</i>
<b>What to do</b>	<i>Products should be removed from service and returned to the point of purchase. Distributors and retailers should discontinue sales and return all inventories to their suppliers.</i>

**Unauthorized Product Photographs – See Page 2**



