



Total Quality. Assured.

545 E Algonquin Road, Suite H
Arlington Heights, IL 60005 USA

Telephone: 847-439-5667
intertek.com

Published:
Revised:

28-Mar-24

Public Notice ID: 2024-12
Page 1 of 2

Misrepresentation of Intertek Certified Product Labels

Fire Doors and Fire Door Frames

Notification Type:	Misuse of Certification Mark
Certification Type:	Not Intertek Certified

Notification

Intertek notifies public that we have been notified by the applicant that the labels identified below have been misrepresented as Intertek Certified.

Company Identification

Masonite Corporation

Product Identification

For misrepresentation of certified product labels. Photos on Page 2

Masonite USA Door (Howell, MI) doors labeled as Intertek W/N 00500 serial numbers 411022, 411192 and 411193 do not conform to the requirements of the standards for the ratings on the label due to the size of the installed lite kit and the end user can contact the manufacturer for support.

Hazard Involved

Not Intertek Certified

What To Do

Use should be immediately discontinued and return to the point of purchase and the labels should be removed and returned to Intertek.



Total Quality. Assured.

545 E Algonquin Road, Suite H
Arlington Heights, IL 60005 USA

Telephone: 847-439-5667

intertek.com

Published: March 28, 2024

Revised:

Public Notice ID: 2024-12

Page 2 of 2

Photos and Images

