# intertek



3933 US Route 11 Cortland, New York 13045 USA Phone Number: (800) 345-3851 Fax Number: (607) 758-6637 Web: www.intertek.com

### ETL Verified Certificate of Conformance Number: 104047595CRT-001

On the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the essential requirements of the referenced specifications at the time the tests were carried out.

Rendered to:

Link Asia Limited

48 Floor 6 Interlink Building Ratchadapisek Road, Samennok Huay Kwang Bangkok, 10310 Thailand

Contact: Mr. Janatpol Surpasongsin

#### **Product Tested:**

6-Connector Channel

| Near End<br>2m<br>1 | $\begin{array}{c} 2m \\ 2m \\ 2 \end{array}$ | 15m 75m<br>4 5 6 5       | Far End<br>2m<br>7<br>2m<br>1<br>8<br>2m<br>1<br>8 |
|---------------------|--|--------------------------|--|
| Component ID        | <u>Manufacturer</u>                          | Part Number              | <u>Description</u>                                 |
| 1                   | Link Asia Limited                            | US-5102-X, US-5102-XLSZH | Patch Cord   |
| 2                   | Link Asia Limited                            | US-1006TFAS, US-4006IL   | Keystone Jack                                      |
| 3                   | Link Asia Limited                            | US-1006STF, US-4006      | Keystone Jack                                      |
| 4                   | Link Asia Limited                            | US-1006SL, US-3124A      | Keystone Jack                                      |
| 5                   | Link Asia Limited                            | US-9116, US-9116LSZH     | Horizontal Cable                                   |
| 6                   | Link Asia Limited                            | US-XXXIDC, US-3124A      | Conjunction Box                                    |
| 7                   | Link Asia Limited                            | US-1006SL, US-3124A      | Patch Panel  |
| 8                   | Link Asia Limited                            | US-4006IL, US-3148A      | Patch Panel  |

**Standard(s)/Specification:** ANSI/TIA-568.2-D and ISO/IEC 11801-1 Category 6 with the applicable electrical transmission characteristics

Product(s) LiteratureETL Verified 6-Connector Channel to ANSI/TIA-568.2-D and ISO/IEC 11801-1May Include:Category 6, along with channel illustration, and parts numbers.

Continuing compliance to this specification is monitored through production testing, ongoing inspections by Intertek at the production facility and random sample testing.

Date Issued: August

August 20, 2019

Approved By:

Antoine Pelletier, Project Engineer

## This verification supersedes all previous verifications with the noted Verification/Report number(s) dated before this verification notice.

#### NOTE: This verification is part of the full test report(s) and should be read in conjunction with it.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.