



Intertek

ETL Verified Certificate of Conformance Number: 103217372CRT-010a

On the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the essential requirements of the referenced specifications at the time the tests were carried out.

Rendered to:

Ningbo Contact Technology Co., Ltd.

No. 8, Chang Feng Qiao Road, Lan Jian Street, Lanshuqiao Village


Yuyao, Zhejiang China

www.ctl.net.cn

Contact: Mr. Winds Tsai

Product Tested:

3-Connector shielded channel



<u>Component ID</u>	<u>Manufacturer</u>	<u>Part Number</u>	<u>Description</u>
1	CTK	N4321-010-01	Equipment Cords
2, 3	CTK	N4435-035-03	Wall Outlet
4	CTK	C38-F9062	F/UTP Horizontal Solid Cable
5	CTK	N4225-094-01	Patch Panel

Standard(s)/Specification: ANSI/TIA-568.2-D Category 6 and ISO/IEC 11801-1 Class E with the applicable electrical transmission characteristics

Product(s) Literature May Include: ETL Verified 3-Connector Channel to ANSI/TIA-568.2-D Category 6 and ISO/IEC 11801-1 Class E, along with channel illustration, and parts numbers.

Continuing compliance to this specification is monitored through production testing, ongoing inspections by Intertek at the production facility and random sample testing.

Date Issued: January 23, 2018

Date Revised: June 24, 2020

Approved By: *Antoine Pelletier*
 Antoine Pelletier, Project Engineer

This verification supersedes all previous verifications with the noted Verification/Report number(s) dated before this verification notice.

NOTE: This verification is part of the full test report(s) and should be read in conjunction with it.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.