



Intertek

ETL Verified Certificate of Conformance Number: 100642818CRT-001c

On the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the essential requirements of the referenced specifications at the time the tests were carried out.

Rendered to:


Rosenberger (Shanghai) Technology Co. Ltd.

Bldg#2, No 303 Xin Ke Road
 Qingpu Industry Park
 Shanghai, China 201707
www.rosenberger.com

Contact: Mr. Laurence Miao

Product Tested:

4-Connector channel



Component ID	Manufacturer	Part Number	Description
1, 9	Rosenberger	CP61-42x-x3	HDCS® Cat6 UTP Patch cord, 3 m
2, 4	Rosenberger	CP31-13x-1x	HDCS® Cat6 UTP Keystone Jack
3	Rosenberger	CP61-42x-x5	HDCS® Cat6 UTP Patch cord, 5 m
5	Rosenberger	CP11-141-1x	HDCS® Cat6 UTP 4-pair LAN Cable, 85 m
6, 8	Rosenberger	CP41-431-03N-P/T	HDCS® Cat6 UTP Modular Patch Panel, 24-Port
7	Rosenberger	CP61-42x-x2	HDCS® Cat6 UTP Patch cord, 2 m

Standard(s)/Specification: ANSI/TIA-568.2-D and ISO/IEC 11801-1 Category 6 with the applicable electrical transmission characteristics

Product(s) Literature May Include: ETL Verified 4-Connector Channel to ANSI/TIA-568.2-D and ISO/IEC 11801-1 Category 6, along with channel illustration, and parts numbers.

Continuing compliance to this specification is monitored through production testing, ongoing inspections by Intertek at the production facility and random sample testing.

Date Issued: April 19, 2012

Date Revised: May 06, 2019

Approved By: *Antoine Pelletier*
 Antoine Pelletier, Project Engineer

This verification supersedes all previous verifications with the noted Verification/Report number(s) dated before this verification notice.

NOTE: This verification is part of the full test report(s) and should be read in conjunction with it.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.