



Total Quality. Assured.

545 E Algonquin Road, Suite H  
Arlington Heights, IL 60005 USA

Telephone: 847-439-5667  
[intertek.com](http://intertek.com)

Published: January 18, 2019  
Revised:

Public Notice ID: 2019-01  
Page 1 of 2

## Misrepresentation of Intertek Certified Product HUK International EST, Listed Fire Door

Notification Type:	Misuse of Certification Mark
Certification Status:	WH Listed

### Notification

Intertek notifies consumers, retailers and distributors that we have been notified by the applicant that the products identified below have been misrepresented as Intertek Certified.

### Company Identification

HUK International EST, Riyadh, Saudi Arabia

### Product Identification

HUK International EST, Listed Fire Door 3/4 Hour Rating, Control Number cWHus 04233

### Product Description

Fire Door with 3/4 hour rating

### Hazard Involved

HUK International's participation in an Intertek Certification Program was terminated in January 2015. It has been discovered that HUK International continued to apply an Intertek certification mark to products produced after this date. It is unknown if the products produced after this date have been tested or meet the requirements of the applicable standard.

### What To Do

Use of these products should be immediately discontinued and return to the point of purchase. Distributors and retailers should discontinue sales and return inventories to their suppliers.

Published: January 18, 2019  
Revised:

Public Notice ID: 2019-01  
Page 2 of 2

**Photos and Images** Photo of Nameplate

