

STANDARD INFORMATION

This SUN establishes the partial superseding of CSA C22.2 No. 205 and introduces ULC 60839-11-1 as the superseding standard for access control panels. This transition is using the continuing certification approach.

Standard: Signal Equipment. CSA C22.2 No. 205

Partially Replaced by Standard: Standard for Alarm and Electronic Security Systems - Part 11-1: Electronic Access Control Systems - System and Components Requirements, ULC 60839-11-1

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: **December 3, 2021**

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: As part of the continuing certification approach, the decision was made that “No Action” is required for products that are currently certified to CSA C22.2 No. 205 (for those products that are currently certified to a combination of UL 294 and CSA C22.2 No 205).

Overview of Changes:

As part of the continuing certification approach, the decision was made that “No Action” is required for products that are currently certified to CSA C22.2 No. 205 (for those products that are currently certified to a combination of UL 294 and CSA C22.2 No 205).

- December 3, 2021 is the effective date. All new and revised products that would have been previously certified **access control products evaluated to CSA C22.2 No. 205** will then be investigated to CAN/ULC 60839-11-1.
- Existing certifications of these products will be allowed to continue to be certified after December 3, 2021 and not be withdrawn provided there are no changes to the physical equipment design or function or until a new/revised requirement in Standard CAN/ULC 60839-11-1 is determined as “Action Required” to require a review in the future. For example, if there are changes to the physical equipment design or function after the effective date, the product (in its entirety) will need to be evaluated to CAN/ULC 60839-11-1.

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.